



Jim Doyle, Governor  
Mary P. Burke, Secretary

September 19, 2007 **REVISED**

ADS-- ADVANCE DRAINAGE SYSTEMS  
ROGER L BALDWIN  
21 CARRIGE LANE  
BURNSVILLE MN 55337-4045

ADVANCED DRAINAGE SYSTEMS, INC.  
SALES  
BRENT A.YEAGER  
1814 PINEVIEW DR.  
VERONA WI 53593

Re: Description: GREASE INTERCEPTOR (also see SEWAGE TANKS)  
Manufacturer: ADVANCED DRAINAGE SYSTEMS, INC.  
Product Name: ADS GREASE INTERCEPTOR  
Model Number(s): 750ANGT  
750 GAL [41.5 IN. L.L.; 96 IN. MAX. DEPTH TO BURY]  
Product File No: 20070403

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of September 2012.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- A minimum 4 x 6 inch permanent label must be affixed to the manhole cover, identifying the interceptor tank with the words GREASE INTERCEPTOR.
- This product is approved to use the following:
  - Eight-inch diameter inlet and outlet openings with tee extensions.
  - Thirty-inch riser, one in each compartment.
  - Nyloplast® 24-inch, locking access covers with counter bored hex bolt fasteners.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.  
PO Box 2658; 201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov